

## Search Results

You are here: [Home](#) » Search Results

### Search by Company Name

#### **Nitin Fire Protection Industries Ltd (NITIE)**

501 Delta  
Technology Street  
Hirandani Gardens, Powai  
Mumbai 400 076  
India

Tel: +91 22 40457000 • Fax: +91 22 66920910  
Email: [systems@nitinfire.com](mailto:systems@nitinfire.com) • Web: [www.nitinfire.com](http://www.nitinfire.com)

#### **Certificate No 855e to EN 12094-5**

### Inertech Selector Valves

Product	Description	LPCB Ref. No.
NF34015	Inertech Selector Valve DN15	855e/17
NF34020	Inertech Selector Valve DN20	855e/17
NF34025	Inertech Selector Valve DN25	855e/17
NF34032	Inertech Selector Valve DN32	855e/17
NF34040	Inertech Selector Valve DN40	855e/17
NF34050	Inertech Selector Valve DN50	855e/17

Note: Selector valves for use with Inertech 60 bar constant discharge regulator (Model Ref NF311250) only. Specified pressure in accordance with note in EN 12094-5 Table 1 is  $\leq 60$  bar for all agents and temperatures.

**[To read the Red Book section introduction click here.](#)**

[< back to results page](#)

[< back to search page](#)



---

The BRE Group website family

BRE Global Approvals listings

[Terms of Use](#) | [How we use cookies](#) | Copyright BRE Global 2017