



## GAQF.EX15341 Clean-agent Extinguishing System Units

[Page Bottom](#)

---

### Clean-agent Extinguishing System Units

[See General Information for Clean-agent Extinguishing System Units](#)

#### **NITIN VENTURES FZE**

EX15341

PO BOX 262294

JEBEL ALI

JAFZA

DUBAI, UNITED ARAB EMIRATES

**ENGINEERED UNITS**, Models NF00035, NF00070, NF00150, NF00250, NF00375, NF00560 and NF01200 HFC-227ea Clean Agent Extinguishing System Units, stored pressure type, having nominal charging capacities of 35, 70, 150, 250, 375, 560 and 1200 lb. HFC-227ea Clean Agent, respectively. These units are super-pressurized to 360 psig with operating temperatures of 32 F to 130 F. The units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure.

These above system units are intended to be designed and installed in accordance with the Listee's Design and Installation Operation and Maintenance Manual, P/N NF000001 Rev 002 dated September 16, 2014. These installations require the use of the Listee's Flow Calculation Software, Version FTF 3.10 (Reference Software User's Manual dated September 2010). Copies of the software and manuals may be obtained from the above Listee.

**ENGINEERED UNITS**, Models NF000015, NF000029, NF000062, NF000103, NF000153, NF000227, NF000368, and NF000490 Novec 1230 Clean Agent Extinguishing System Units, stored pressure type, having nominal charging capacities of 38, 75, 160, 270, 400, 600, 950, and 1300 lb. Novec 1230 Clean Agent, respectively. These units are super-pressurized to 500 psig with operating temperatures of 32 F to 130 F. The units are designed for total flooding protection against Class A surface burning, Class B flammable liquid and Class C fires occurring within an enclosure.

These above system units are intended to be designed and installed in accordance with the Listee's Design and Installation Operation and Maintenance Manual, P/N NF000003 Rev 002 dated March 17, 2015. These installations require the use of the Listee's Flow Calculation Software, VdS Novec 1230, Version 7.5 (Reference Software User's Manual dated April 2010). Copies of the software and manuals may be obtained from the above Listee.

[Last Updated](#) on 2015-04-24

---

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2017 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2017 UL LLC".